



## CB TEST CERTIFICATE

Ref. Certificate No.

NL-10968

### IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Registration date:	2006-07-25		
Product:	Circuit-breaker for overcurrent protection		
Applicant:	Indo Asian Fusegear Limited	B-200, Phase II Noida - 201305, U.P.	India
Manufacturer:	Indo Asian Fusegear Limited	B-200, Phase II Noida - 201305, U.P.	India
Factory:	Indo Asian Fusegear Limited	B-200, Phase II Noida - 201305, U.P.	India
Rating and principal characteristics:	240/415 Vac, Type C: 0.5 A till 63 A, Typ B: 6 A till 63 A, Ics 7500 A, Icn 10000 A, 1-pole, 1-pole +N, 2-pole, 3-pole, 3-pole +N, 4-pole		
Trade mark (if any):	INDO KOPP or HAUSMANN		
Model/Type reference:	B...., C.... (Character B or C followed by the rated current)		
Additional information:	Energy limiting class: 3 (according to EN 60898-1:2003+A1:2004)		
Sample of product tested to be in conformity with IEC:	60898-1(Consolidated ed.1.2)		
Test Report Ref. No:	2094032.50, 2094032.51, 2094032.52		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

Signed by: H. H. M. Versteegen

Date of issue: 2006-07-25

