



CERTIFICATE

KEMA No.: 2094032.01

Issued to:
Applicant:

**Indo Asian Fusegear Ltd.
B-200, Phase II,
NOIDA 201305, U.P., India**



Manufacturer/Licensee:
**Indo Asian Fusegear Ltd.
B-200, Phase II,
NOIDA 201305, U.P., India**

Product(s) : circuit-breakers for overcurrent protection
Trade name(s) : HAUSMANN,
INDO KOPP
Type(s)/model(s) : B...,
C...

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60898-1:2003;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2094032

KEMA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: July 31, 2006 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

P. Nabuurs
Managing director

H.H.M. Versteegen
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	:	circuit-breakers for overcurrent protection
trade name(s)	:	HAUSMANN, INDO KOPP
type(s)	:	B..., C...
rated current (In)	:	Type B: 6, 10, 16, 20, 25, 32, 40, 50, and 63 A. Type C: 0.5, 1, 2, 3, 4, 5, 6, 10, 16, 20, 25, 32, 40, 50 and 63 A.
rated voltage (Un)	:	240/415 Vac
number of poles	:	1, 1+N, 2, 3, 3+N, 4
range of instantaneous tripping overcurrent	:	Type B or Type C
rated short-circuit capacity (Icn)	:	10000 A
rated service short- circuit capacity (Ics)	:	7500 A
energy limiting class	:	3
temperature limit	:	-5 to 40 °C
method of mounting	:	flush type
degree of protection against moisture	:	ordinary

Additional information

Structure of the type designation:
Character B or C followed by the rated current

TESTS

Test requirements
EN 60898-1:2003

Test result

The test results are laid down in KEMA test file 2094032.01.

Conclusion

The examination proved that all test requirements were met.

Tested by : B.P. Aggerwal
Checked by : H.H.M. Versteegen

**Factory-Locations**

Indo Asian Fusegear Ltd.,
B-200, Phase II, NOIDA 201305, U.P., India